



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009. Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/003

Date : 08-04-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 03-04-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.36	6.5 – 9.0
2	Total Suspended Solids	18.00	20.00
3	Ammonical Nitrogen	4.70	5.00
4	Total Nitrogen	9.05	10.00
5	COD	46.00	50.00
6	BOD	8.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009 Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/038

Date : 27-05-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 22-05-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.22	6.5 – 9.0
2	Total Suspended Solids	16.00	20.00
3	Ammonical Nitrogen	4.55	5.00
4	Total Nitrogen	9.00	10.00
5	COD	42.00	50.00
6	BOD	7.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009. Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/059

Date : 24-06-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 19-06-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.80	6.5 – 9.0
2	Total Suspended Solids	19.00	20.00
3	Ammonical Nitrogen	4.15	5.00
4	Total Nitrogen	8.95	10.00
5	COD	44.00	50.00
6	BOD	8.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009. Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/066

Date : 13-07-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 07-07-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.40	6.5 – 9.0
2	Total Suspended Solids	19.00	20.00
3	Ammonical Nitrogen	4.80	5.00
4	Total Nitrogen	9.25	10.00
5	COD	47.00	50.00
6	BOD	9.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009. Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/100

Date : 30-08-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 23-08-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.44	6.5 – 9.0
2	Total Suspended Solids	18.00	20.00
3	Ammonical Nitrogen	4.75	5.00
4	Total Nitrogen	9.10	10.00
5	COD	42.00	50.00
6	BOD	8.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)



**AKSHAR
CONSULTANTS**

THE ENVIRONMENT MANAGEMENT PEOPLE

704 & 813, Sakar-5, Nr. Mithakhali Railway Crossing, Off Ashram Road, Ahmedabad - 380 009. Tel/Fax : (079) 26583525

Ref. No. AC/EFF/17-18/119

Date : 26-09-2017

Intas Pharmaceuticals Ltd.,
Plot No. 457, 458, Sarkhej – Bavala Highway,
Vil. : Matoda – 382 210, Ta. : Sanand,
Dist. : Ahmedabad.

Sub. : ANALYSIS REPORT OF YOUR TREATED SEWAGE SAMPLE.

Sample drawn by : Akshar Consultants.
Sample collection date : 20-09-2017.

Sr. No.	Parameter	Result	GPCB Limit
1	pH	7.30	6.5 – 9.0
2	Total Suspended Solids	17.00	20.00
3	Ammonical Nitrogen	4.90	5.00
4	Total Nitrogen	9.75	10.00
5	COD	45.00	50.00
6	BOD	8.00	10.00

Note : All parameters except pH are expressed in mg/L.

ANALYSED BY,

(Analyst)

For AKSHAR CONSULTANTS,

(Authorised Signatory)